

## ILA REPORT



**INDUSTRIAL LAB ANALYSIS, INC.**  
2240 Williamsburg Drive  
Glen Dale, WV 26038  
304-233-5595

**Approved By: IM/BM**

Company: <b>Century Mining</b> Pit Identification: Sewage Treatment Plant Sampling Point: 601 STP Effluent Sample Collected By: BD Time & Date Collected: 10-11-06 @ 1400	Sample No.: <b>06-10-628</b> Date Received: 10-11-06 Date Reported: 10-26-06 Analyzed By: IM/BM <i>[Signature]</i>
---	---

Parameter	Result	Units	M D L	Ref MC	Preservative
C BOD <sub>5</sub> Day	< 5.0	mg/l	5.0	405.1	None
T S S	< 1.0	mg/l	2.0	160.2	None
Ammonia	< 0.50	mg/l	0.5	350.2	H <sub>2</sub> SO <sub>4</sub>

Ref. MC: Standard Methods for Examination of Water and Wastewater, 18<sup>th</sup> Edition, and  
US EPA Methods for Chemical Analysis of Water and Waste.